

2020 Annual Drinking Water Quality Report

Town of Benson

Water System Number: 03-51-025

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your sources of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Town Hall at 919-894-3553. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at the Municipal building on the second Tuesday of each month at 7 PM.**

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Benson is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by this system is purchased surface water from the Cape Fear and Neuse River.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environmental Quality (DEQ), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for the Town of Benson was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Dunn, City of	Higher	Sep 10,2020
Johnston Co-East	Higher	Sep 10,2020
Johnston Co-West	Higher	Sep 10,2020

The complete SWAP Assessment report for the Town of Benson may be viewed on the Web at: <https://www.ncwater.org/?page=600> Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water sources in several ways: (examples: dispose of chemicals properly, take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc.)

Violations that Your Water System Received for the Report Year

The Town of Benson received no violations for the 2020 compliance period.

Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2020.** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Important Drinking Water Definitions:

Not-Applicable (N/A) – Information not applicable/not required for that particular water system or for that particular rule.

Non-Detects (ND) - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/L) - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/L) - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Million Fibers per Liter (MFL) - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfection Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfection Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Locational Running Annual Average (LRAA) – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Tables of Detected Contaminants

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	6/01/19 9/30/19	0.118	0	1.3	AL = 1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 th percentile)	6/01/19 9/30/19	ND	0	0	AL = 15	Corrosion of household plumbing systems; erosion of natural deposits

Revised Total Coliforms Rule:

Microbiological Contaminants in the Distribution System - For systems that collect *less than 40* samples per month

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	Absent	0	TT*	Naturally present in the environment
<i>E. coli</i> (presence or absence)	N/A	N/A	0	Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> <u>Note:</u> If either an original routine sample and/or its repeat samples(s) are <i>E. coli</i> positive, a Tier 1 violation exists.	Human and animal fecal waste

* If a system collecting fewer than 40 samples per month has two or more positive samples in one month, an assessment is required.

Disinfectant Residuals Summary

Disinfectant (units)	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
				Low	High			
Chlorine (ppm)	2020	N	0.61	0.29	0.97	4	4.0	Water additive used to control microbes
Chloramines (ppm)	2020	N	2.04	0.87	3.32	4	4.0	Water additive used to control microbes

Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)

Disinfection Byproduct (units)	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)								Byproduct of drinking water disinfection
Location B01	2020	N	41	22	41	N/A	80	
Location B02	2020	N	37	20	37	N/A	80	
HAA5 (ppb)								Byproduct of drinking water disinfection
Location B01	2020	N	25	ND	25	N/A	60	
Location B02	2020	N	17	12	24	N/A	60	

For TTHM: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

For HAAS: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

2020 Annual Drinking Water Quality Report City of Dunn

Water System Number: NC 03-43-010

Tables of Detected Contaminants

Turbidity*

Contaminant (units)	Treatment Technique (TT) Violation Y/N	Your Water	MCLG	Treatment Technique (TT) Violation if:	Likely Source of Contamination
Turbidity (NTU) - Highest single turbidity measurement	N	0.20 NTU	N/A	Turbidity > 1 NTU	Soil runoff
Turbidity (NTU) - Lowest monthly percentage (%) of samples meeting turbidity limits	N	100 %	N/A	Less than 95% of monthly turbidity measurements are ≤0.3 NTU	

* Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Fluoride (ppm)	1/23/20	N	0.45	N/A		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	7/6/19-8/7/19	0.115	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 th percentile)	7/6/19-8/7/19	ND	0	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Radiological Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Beta/photon emitters (pCi/L)	10/01/18	N	4.4	N/A		0	50 *	Decay of natural and man-made deposits

* Note: The MCL for beta/photon emitters is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.

Total Organic Carbon (TOC)

Contaminant (units)	TT Violation Y/N	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	TT	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	N	1.31	1.15-1.54	N/A	TT	Naturally present in the environment	Step 1

Disinfectant Residuals Summary

	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
				Low	High			
Chlorine (ppm)	2020	N	0.7	0.1	2.6	4	4.0	Water additive used to control microbes
Chloramines (ppm)	2020	N	2.00	0.6	3.2	4	4.0	Water additive used to control microbes

Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)						N/A	80	Byproduct of drinking water disinfection
Location								
B01	2020	N	30.0	17.0	33.8	N/A	80	Byproduct of drinking water disinfection
B02	2020	N	29.3	15.9	38.6	N/A	80	Byproduct of drinking water disinfection
B03	2020	N	29.8	16.3	35.1	N/A	80	Byproduct of drinking water disinfection
B04	2020	N	30.3	17.0	37.1	N/A	80	Byproduct of drinking water disinfection
Location								
B01	2020	N	27.6	20.0	35.1	N/A	60	Byproduct of drinking water disinfection
B02	2020	N	25.6	19.5	32.2	N/A	60	Byproduct of drinking water disinfection
B03	2020	N	27.3	20.8	33.9	N/A	60	Byproduct of drinking water disinfection
B04	2020	N	27.3	23.7	30.5	N/A	60	Byproduct of drinking water disinfection

For TTHM: *Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.*

For HAA5: *Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.*

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

Other Miscellaneous Water Characteristics Contaminants

Contaminant (units)	Sample Date	Your Water	Range		SMCL
			Low	High	
Iron (ppm)	2020	ND	N/A		0.3 mg/L
Manganese (ppm)	2020	ND	N/A		0.05 mg/L
Sodium (ppm)	2020	25.84	N/A		N/A
Sulfate (ppm)	2020	34.10	N/A		250 mg/L
pH	2020	6.9	N/A		6.5 to 8.5

Cryptosporidium

Our system monitored for *Cryptosporidium* and found levels of 0.011 Oocyst.per liter.

Sample Date	Your Water (average)	Range	
		Low	High
2018	0.011	0.00	.286

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes *Cryptosporidium*, the most commonly-used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water and/or finished water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease, and it may be spread through means other than drinking water.

Additional Monitoring of Other Contaminants

LT2 Monitoring Giardia / 0.127 Cysts per Liter in the Untreated Raw Water.

Sample Date	Your Water (average)	Range	
		Low	High
2018	0.027	0.00 - 1.05	

LT2 Monitoring E Coli / 114.2 CFU per Liter in the Untreated Raw Water

Sample Date	Your Water (average)	Range	
		Low	High
2018	114.2	6.3 - 1733	

Unregulated Contaminants / UCMR4

Entry Point 1

Contaminant (units)	Sample Date	Your Water	Range	
			Low	High
Micocystins (ug/L)	2019	ND	N/A	

Sample Point 50

Contaminant (units) ppb	Sample Date	Your Water	Range	
			Low	High
Bromochloroacetic Acid (ppb)	2019	8.36	6.62 - 12	
Bromodichloroacetic Acid (ppb)	2019	6.58	4.46 - 10.3	
Chlorodibromoacetic Acid (ppb)	2019	2.28	1.64 - 2.67	
Dibromoacetic Acid (ppb)	2019	2.67	1.13 - 5.14	
Dichloroacetic Acid (ppb)	2019	13.03	7.04 - 16.7	
Monobromoacetic Acid (ppb)	2019	0.136	0.00 - 0.545	

Monochloroacetic Acid (ppb)	2019	ND	N/A
Tribromoacetic Acid (ppb)	2019	0.625	0.0 - 2.50
Trichloroacetic Acid (ppb)	2019	8.92	3.57 - 21.5

Sample Point 150

Contaminant (units) ppb	Sample Date	Your Water	Range	
			Low	High
Bromochloroacetic Acid (ppb)	2019	7.43	4.78	11.5
Bromodichloroacetic Acid (ppb)	2019	5.3	4.16	9.28
Chlorodibromoacetic Acid (ppb)	2019	2.95	1.44	5.33
Dibromoacetic Acid (ppb)	2019	2.68	1.08	5.67
Dichloroacetic Acid (ppb)	2019	10.3	13.21	5.44
Monobromoacetic Acid (ppb)	2019	0.24	0.00	0.627
Monochloroacetic Acid (ppb)	2019	ND	N/A	
Tribromoacetic Acid (ppb)	2019	1.56	0.00	3.45
Trichloroacetic Acid (ppb)	2019	7.55	3.67	17.1

Sample Point L26

Contaminant (units) ppb	Sample Date	Your Water	Range	
			Low	High
Bromochloroacetic Acid (ppb)	2019	8.29	5.64	12.2
Bromodichloroacetic Acid (ppb)	2019	6.51	4.30	9.81
Chlorodibromoacetic Acid (ppb)	2019	2.32	2.00	2.79
Dibromoacetic Acid (ppb)	2019	2.87	1.08	5.62
Dichloroacetic Acid (ppb)	2019	13.38	6.92	16.8
Monobromoacetic Acid (ppb)	2019	0.222	0.00	0.545
Monochloroacetic Acid (ppb)	2019	ND	N/A	
Tribromoacetic Acid (ppb)	2019	0.735	0.00	2.94
Trichloroacetic Acid (ppb)	2019	8.68	3.81	21.5

Sample Point L24

Contaminant (units) ppb	Sample Date	Your Water	Range	
			Low	High
Bromochloroacetic Acid (ppb)	2019	8.9	6.04	13.9
Bromodichloroacetic Acid (ppb)	2019	6.85	4.52	9.92
Chlorodibromoacetic Acid (ppb)	2019	2.73	1.75	4.88
Dibromoacetic Acid (ppb)	2019	2.93	1.13	6.03
Dichloroacetic Acid (ppb)	2019	15.09	7.07	20.6
Monobromoacetic Acid (ppb)	2019	0.256	0.00	0.541
Monochloroacetic Acid (ppb)	2019	0.057	0.00	0.226
Tribromoacetic Acid (ppb)	2019	1.23	0.00	2.88
Trichloroacetic Acid (ppb)	2019	9.53	3.75	22.8

Sample Point EP1

Contaminant (units) ppb	Sample Date	Your Water	Range	
			Low	High
Manganese (ppb)	2019	3.45	1.18	5.73

Sample Point S01

Contaminant (units) ppb	Sample Date	Your Water	Range	
			Low	High
Bromide (ppb)	2019	143.4	93.8	193
Total Organic Carbon (TOC) (ppb)	2019	6040	5780	6300



2020 Annual Drinking Water Quality Report
 Johnston County Public Utilities
 PWS # 40-51-018 EAST
 PWS # 03-51-070 WEST



Water Quality Data Table(s) Johnston County WEST PWS# 03-51-070: 2020

Disinfectant Residuals Summary 2020								
Contaminant(units)	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
				Low	High			
Chlorine (ppm)	2020	N	0.56	0.06	3.67	4	4.0	Water additive used to control microbes
Chloramines (ppm)	2020	N	2.75	0.0	3.93	4	4.0	Water additive used to control microbes

Stage 2 Stage 2 Disinfection Byproduct Compliance – Based on Locational Running Annual Average (LRAA) 2020									
Disinfection Byproduct	Units	MCLG	MCL	Your Water (highest LRAA)	Range		Year Sampled	MCL Violation (Yes / No)	Likely Source of Contamination
					Low	High			
TTHM	ppb	N/A	80	35			2020	No	Byproduct of drinking water disinfection
B01					21	44			
B02					15	30			
B03					23	47			
B04					17	33			
B05					21	38			
B06					20	33			
B07					19	39			
B08					24	52			
HAA5	ppb	N/A	60	26			2020	No	Byproduct of drinking water chlorination
B01					18	25			
B02					15	23			
B03					18	34			
B04					14	18			

B05					14 - 23			
B06					12 - 17			
B07					14 - 26			
B08					21 - 30			

For TTHM: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys or central nervous systems, and may have an increased risk of getting cancer.

For HAA5: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased chance of getting cancer

Inorganic Contaminants 2020

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Fluoride (ppm)	March 2020	N	0.31	N/A		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Synthetic Organic Chemical (SOC) Contaminants including Pesticides and Herbicides 2020

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Simazine (ppb)	2020	N	0.08	0.0 – 0.17		4	4	Herbicide runoff

Lead and Copper Contaminants: Pregnant women, infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

Contaminant	Units	Sample Date	Your Water	# of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (90 th percentile)	ppm	July 2018	0.119	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (90 th percentile)	ppb	July 2018	0	0	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Total Organic Carbon (TOC): Depending on the TOC in our source water, the system MUST have a certain % removal of TOC or must achieve alternative compliance criteria. If we do not achieve that % removal, there is an alternative % removal. If we fail to meet the alternative % removal, we are in violation of a Treatment Technique. (2020)

Contaminant (units)	TT Violation Yes/No	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	MCL	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon	No	1.36	1.30 – 1.54	N/A	TT	Naturally Present in the environment	Step 1

Step 1 TOC Removal Requirements (%)

Source Water TOC (mg/L)	Source Water Alkalinity Mg/L as CaCO3 (in percentages)		
	0 – 60	> 60 – 120	> 120
> 2.0 – 4.0	35.0	25.0	15.0
> 4.0 – 8.0	45.0	35.0	25.0
> 8.0	50.0	40.0	30.0

Water Characteristics Contaminants: The PWS section requires monitoring of other misc contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic or aesthetic effects (such as taste, odor, and or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

Contaminant (units)	Sample Date	Your Water	Range Low High	Secondary MCL
Sodium (ppm)	March 2020	36.8	N/A	N/A
pH	March 2020	6.5	N/A	6.5 to 8.5

Smithfield Water Treatment Plant 2020 Data		
Susceptibility of Sources to Potential Contaminant Sources (PCSs)		
Source Name	Susceptibility Rating	SWAP Report Date
Neuse River	Higher	September 2020

Water Quality Data Table(s) Town of Smithfield Water Treatment Plant: 2020 (Purchased)

Town of Smithfield Water Treatment Plant 2020 Data					
Contaminant	Units	Level Detected	Range		Sample Date
			Low	High	
Haloacetic Acids (Haa5)	ppb	37.0 (AVG)	24.8	51.8	2020
Total Trihalomethanes (TTHMs)	ppb	34.0 (AVG)	24.0	65.0	2020
Chloramines	ppm	3.42	0	3.4	2020
Chlorine	ppm	1.46	0.98	1.55	2020
Fluoride	ppm	<0.01	N/A		2020

Turbidity	NTU	0.221 (highest)	100% of samples below limit	2020
Copper	ppm	0.122 (90 th percentile)	N/A	2019
Lead	ppb	0.008 (90 th percentile)	N/A	2019
Sulfate	ppm	37.0	N/A	2020
pH	N/A	7.9	N/A	2020
Sodium	ppm	27.23	N/A	2020
Simazine	ppb	0.1	0.0 – 2.4	2020

Step 1 TOC Removal Requirements (%)			
Source Water TOC (mg/L)	Source Water Alkalinity Mg/L as CaCO ₃ (in percentages)		
	0 – 60	> 60 – 120	> 120
> 2.0 – 4.0	35.0	25.0	15.0
> 4.0 – 8.0	45.0	35.0	25.0
> 8.0	50.0	40.0	30.0

Alternative Compliance Criteria (ACC)

Alt 1	Source Water TOC <2.0 mg/L
Alt 2	Treated Water TOC < 2.0 mg/L
Alt 3	Source Water SUVA ≤ 2.0 L/mg-m
Alt 4	Treated Water SUVA ≤ 2.0 L/mg-m
Alt 5	Treated Water Alkalinity < 60 mg/L (for softening systems only)
Alt 6	THM & HAA RAA's ≤ 1/2 MCL & uses only chlorine
Alt 7	Source TOC RAA < 4.0 mg/L and Source Alkalinity > 60 mg/L and THM & HAA RAAs ≤ 1/2 MCL

Town of Smithfield Water Treatment Plant Disinfection Byproduct Precursors Contaminants 2020 Data							
Contaminant (units)	TT Violation Yes/No	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	MCL	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	No	1.19	1.06 – 1.45	N/A	TT	Naturally present in the environment	Step 1 and Alt.#4

Water Quality Data Table(s) Johnston County East PWS# 40-51-018: 2020

Stage 2 Disinfectant Byproduct Compliance- Based on Locational Running Average (LRAA) 2020								
Disinfection Byproduct	Units	MCLG	MCL	Your Water (highest LRAA)	Range Low High	Year Sampled	MCL/ Violation (Yes / No)	Likely Source of Contamination
TTHM	ppb	N/A	80	68		2020	No	Byproduct of drinking water disinfection
B01					28 - 84			
B02					30 - 110			
B03					32 - 106			
B04					10 - 39			
HAA5	ppb	N/A	60	33		2020	No	Byproduct of drinking water chlorination
B01					21 - 35			
B02					26 - 42			
B03					26 - 33			
B04					2 - 16			

Inorganic Contaminants								
Fluoride	ppm	4	4	0.22	N/A	2020	No	Erosion of natural deposits; Water additive which promote strong teeth; discharge from fertilizer and aluminum factories

For TTHM: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.
For HAA5: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased chance of getting cancer.

Lead and Copper Contaminants: Pregnant women, infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

Contaminant	Units	Sample Date	Your Water	Number of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (90 th percentile)	ppm	July 2020	0.113	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (90 th percentile)	ppb	July 2020	0	0	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Turbidity*	Treatment Technique (TT) Violation Y/N	Your Water	MCLG	Treatment Technique (TT) Violation if:	Likely Source of Contamination
Contaminant (units)					
Turbidity (NTU) - Highest single turbidity measurement	N	0.115 NTU	N/A	Turbidity > 1 NTU	Soil runoff
Turbidity (NTU) - Lowest monthly percentage (%) of samples meeting turbidity limits	N	100 %	N/A	Less than 95% of monthly turbidity measurements are ≤ 0.3 NTU	

Disinfectant Residuals Summary							
Contaminant (units)	Year Sampled	MRDL Violation	Your Water	Range	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	2020	N	1.58	0.2 – 3.41	4	4.0	Water additive used to control microbes

Total Organic Carbon (TOC): Depending on the TOC in our source water, the system MUST have a certain % removal of TOC or must achieve alternative compliance criteria. If we do not achieve that % removal, there is an alternative % removal. If we fail to meet the alternative % removal, we are in violation of a Treatment Technique. (2020)

Contaminant (units)	TT Violation Yes/No	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	MCL	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	No	1.44	1.35 – 1.71	N/A	TT	Naturally present in the environment	Step 1

Step 1 TOC Removal Requirements (%)			
Source Water TOC (mg/L)	Source Water Alkalinity Mg/L as CaCO3 (in percentages)		
	0 – 60	> 60 – 120	> 120
> 2.0 – 4.0	35.0	25.0	15.0
> 4.0 – 8.0	45.0	35.0	25.0
> 8.0	50.0	40.0	30.0

Water Quality Data Table(s) Harnett County Water Treatment Plant: 2020 Water (Purchased)

Water Characteristics Contaminants: The PWS section requires monitoring of other misc contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic or aesthetic effects (such as taste, odor, and or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

Contaminant (units)	Sample Date	Your Water	<i>Range</i>		Secondary MCL
			Low	High	
Sodium (ppm)	April 2020	31.1	N/A		N/A
pH	April 2020	7.4	N/A		6.5 to 8.5

Harnett County Water Treatment Plant 2020 Data

<i>Contaminant</i>	Units	Level Detected	Range Low High	Sample Date
Chloramines	ppm	2.85	1.10 – 4.50	2020
Chlorine(only month of March)	ppm	1.75	0.2 – 2.90	2020
Fluoride	ppm	0.75	N/A	2020
Turbidity	NTU	0.04 (highest)	100% of samples below limit	2020
Copper	ppm	0.097 (90 th percentile)	N/A	2019
Lead	ppb	ND (90 th percentile)	N/A	2019
Sulfate	ppm	44.1	N/A	2020
pH	N/A	7.6	N/A	2020
Sodium	ppm	22.69	N/A	2020
Chlorite(Distribution)	ppm	0.402	0.347 – 0.450	2020
Chlorine Dioxide	ppb	22.0	0 - 237	2020

--	--	--	--	--

Step 1 TOC Removal Requirements (%)			
Source Water TOC (mg/L)	Source Water Alkalinity Mg/L as CaCO3 (in percentages)		
	0 – 60	> 60 – 120	> 120
> 2.0 – 4.0	35.0	25.0	15.0
> 4.0 – 8.0	45.0	35.0	25.0
> 8.0	50.0	40.0	30.0

Harnett County Water Treatment Plant Disinfection Byproduct Precursors Contaminants 2020 Data							
Contaminant (units)	TT Violation Yes/No	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	MCL	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	No	1.43	1.20 – 1.64	N/A	TT	Naturally present in the environment	Step 1

Harnett County Water Treatment Plant Disinfection Byproduct Precursors Contaminants 2019 Data

Contaminant (units)	TT Violation Yes/No	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	MCL	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED	No	1.44	1.20 – 1.64	N/A	TT	Naturally present in the environment	Step 1

Harnett County Water Treatment Plant Microbiological Contaminants 2020					
Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	3.0%	0	>5% triggers level 1 assessment	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (presence or absence)	N	0%	0	Routine and repeat samples are total coliform positive and either is E. coli-positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli <u>Note:</u> if either an original routine sample and/or its repeat sample(s) are E. coli positive, a Tier 1 violation exists.	Human and animal fecal waste

Stage 2 Disinfectant Byproduct Compliance- Based on Locational Running Average (LRAA) Harnett County 2020									
Disinfection Byproduct	Units	MCLG	MCL	Your Water (highest LRAA)	Range		Year Sampled	MCL/ Violation (Yes / No)	Likely Source of Contamination
					Low	High			
TTHM	ppb	N/A	80	38.2			2020	No	Byproduct of drinking water disinfection
B01					19.9	39.6			
B02					21.4	40.8			
B03					17.1	28.6			
B04					15.7	48.7			
B05					22.2	42.6			
B06					21.5	40.6			
B07					20.0	37.4			
B08					20.3	43.9			
HAA5	ppb	N/A	60	23.7			2020	No	Byproduct of drinking water chlorination
B01					13.8	22.7			
B02					17.4	28.6			
B03					12.9	19.1			
B04					17.7	30.2			
B05					14.1	19.3			
B06					14.0	17.6			
B07					12.6	19.6			
B08					14.3	23.7			
<p>For TTHM: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.</p> <p>For HAA5: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased chance of getting cancer.</p>									

Unregulated UCMR 4 Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

Johnston County West PWS# 03-51-070 UCMR4 2020

Contaminant (units)	Sample Date(s)	Your Water (average)	Range	
			Low	High
Bromochloroacetic acid (ppb)	January, April, July, October 2020	5.28	3.0	7.7
Bromodichloroacetic acid (ppb)	January, April, July, October 2020	2.63	0.79	3.6
Chlorodibromoacetic acid (ppb)	January, April, July, October 2020	0.96	ND	1.9
Germanium	January, April, July, October 2020	0.27	0.31	0.75

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in the water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. Our staff in the Johnston County Utility Department work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

www.johnstonnc.com/ccr

