



RECONNECTION UTILITY REQUEST

TOWN OF BENSON PLANNING AND ZONING DEPARTMENT
303 EAST CHURCH STREET, BENSON, NC 27504
919-894-3553 FAX 919-894-1283

Application Date _____

Applicant Name (if different than owner) _____ Applicant Phone No. _____

Owner Name _____ Phone _____

Site Address _____ Benson, NC 27504

Reason for Reconnection: New Move In _____ Construction _____ Other: explain _____

How long has service been disconnected from this location? _____

Type of Structure: Single-Family Dwelling Duplex Townhome Commercial

Utility Type:

Electric Utility Company _____ Premise No. _____

Water Utility Company _____

Gas Utility Company _____

BY MAKING THIS REQUEST THE APPLICANT AND/OR OWNER OF SAID PROPERTY UNDERSTANDS THAT THIS REQUEST SHALL REQUIRE AN INSPECTION OF THE ENTIRE STRUCTURE AND THAT THEY FULLY UNDERSTAND THAT ANY SIGN OF DAMAGE, DETERIORATION OF THE STRUCTURE IN TERMS OF STRUCTURAL, ELECTRICAL, MECHANICAL, GAS PIPING, PLUMBING, AND ANY OTHER RELEVANT TECHNICAL CHARACTERISTIC OF THIS STRUCTURE MAY REQUIRE ADDITIONAL REPAIR WORK AND APPLICABLE PERMITS TO ASSURE THERE ARE NO IMMINENT DANGERS TO THE OCCUPANTS OF SAID STRUCTURE.

I HAVE READ AND UNDERSTAND THE STATEMENT ABOVE

Applicant Signature _____ Date _____

ELECTRICAL RECONNECT REQUIREMENTS

INSPECTION CONSISTS OF THE FOLLOWING:

- 1. Address on building (Minimum 4" letters/numbers).**
- 2. All switches and receptacles to have a cover plate and in working order.**
- 3. No exposed electrical wiring.**
- 4. Electrical conduit and wiring cable to be supported.**
- 5. All electrical breaker boxes to have all knock-outs properly plugged and supported.**
- 6. Main electrical breaker box to have a main breaker and dead front cover.**
- 7. Use of extension cord to be 6' or less in length, and not running across doorways, etc.**
- 8. All light fixtures to be properly supported and enclosed.**
- 9. All exit light fixtures to be in good working order.**
- 10. All emergency powered lights to be tested by pushing the test button. At that time, the direct current bulbs will have to light up.**
- 11. Proper ground rod and connection.**
- 12. Three feet of free working clearance in front and sides of all electrical service equipment.**
- 13. Some or all of these items may require an electrical permit. Only a licensed electrician, licensed by the state of North Carolina may perform the work.**